3 WIRE MOTOR WITH CIRCUIT & FEATURE BOARD



NOTES:

1. Motor is rated at 10 Amps use appropriate wire size throughout the system.
2. Use 15 amp GFCI breaker at panel.
3. Follow all applicable codes.
4. Change motor direction by switching directional wires at the kEy switch
5. Two all-weather boxes and conduits are required in the mechanism pit so that the high and low voltage wires are not run together in the same conduit.
6. Water feature rating = 20 amps Normally open, 10 amps Normally closed

9-23-2004